



ECU[®]

**SUSTAINABLE ENERGY
AND ENVIRONMENTAL
ENGINEERING**

**Details for follow-up activities: Rectangular Evase
Recommendation**

Installation & Labour

The installation of a rectangular evase is simple, but when fabricating a new rectangular evase, the experienced welder should take measurements for which disassembling of cyclone dust collector may be needed. A total of 2 days may be required to disassemble, weld the rectangular evase, and to perform tests. It is approximated that 2 welders and 2 helpers for 2 days that charge \$75 per hour and \$45 per hour respectively. Assuming 8 hour work days, and neglecting travel costs for the workers, the total estimated cost is \$1,920.

Implementation Schedule

Aforementioned, if properly planned, the work can be completed in 2 days. It should be noted that the normal workflow and production rate may be affected during installation. Therefore, it is recommended, if possible, to schedule the installation during a non-working day.

Energy saving cost

Assuming the following:

- Volumetric Air Flow: 4.72 m³/s
- Average Pressure Reduction: 40 Pa

And substituting into the equation below,

$$\text{Savings in Air Power} = \text{Volumetric Air Flow} * \text{Average Pressure Reduction}$$

The savings in Air Power yield **188.8 W**.

Assuming the following:

- Cyclone operates 10 hrs per day
- Cyclone operated 251 days per year

And substituting values into the equation below:

$$\text{Savings in Air Power per day} = 188.8 * 10 = \mathbf{1.888 \text{ kWh}}$$

$$\text{Annual savings in Air Power} = 1.888 * 251 = \mathbf{473 \text{ kWh}}$$

With the following assumptions:

- Savings in Air Power: 188.8 W
- Fan Efficiency: 55%
- Motor Efficiency: 95%

the following equations can be used to calculate the electrical power savings (in kWh)

$$\text{Electrical Power Savings} = \text{Savings in Air Power} / (\text{Fan Efficiency} * \text{Motor Efficiency})$$

$$\text{Electrical Power Savings} = (188.8) / (0.55 * 0.95) = \mathbf{361 \text{ W}}$$

With the following assumptions:

- Cyclone operates 10 hrs per day
- Cyclone operates 251 days per year

The electrical power savings per day can be calculated with the following equation

$$\text{Electrical Power Savings} = 361 * 10 = \mathbf{3.61 \text{ kWh}}$$

$$\text{Annual savings in Electrical power} = 3.61 * 251 = \mathbf{906 \text{ kWh}}$$

And therefore, with the cost of electricity equalling \$0.06 per kWh, the annual savings in electrical power savings are approximately \$55.

Success Stories [1]

A study conducted by P.A Funk from U.S department of Agriculture observed that there has been a pressure drop in a cyclone that can be reduced by between 8.7 and 11.9% with the addition of a radial evase. This accounted for savings in energy.

- Evasés may reduce cyclone pressure drop without affecting collection efficiency.
- Investment in an evasé can be recovered through reduced operating energy costs

Welders

Company	Location	Phone	Website
Karnel Inc	Nescopeck, PA	570-586-1488	Here
Genesis Metalworks	Lexington, NC	336-238-5760	Here
Hardee & Cox Welding, Inc	Greenville, NC	252-355-5007	Here
Wahlen's Mobile Welding	Greenville, NC	252-902-4082	Here

References

- [1] P. A. Funk, "Reducing cyclone pressure drop with evasés," *Powder Technol.*, vol. 272, pp. 276–281, Mar. 2015.